



Trust our People. Trust our Data.
www.energylab.com

Billings, MT 800.735.4489 • Casper, WY 888.235.0515
Gillette, WY 866.686.7175 • Helena, MT 877.472.0711

LABORATORY ANALYTICAL REPORT

Prepared by Billings, MT Branch

Client: Malta City of
Project: MT0000284
Client Sample ID: Hardware Hank
PWS ID: MT0000284 **Facility ID:** DS001 **Sample Point ID:** SP001
Facility Name: MALTA CITY OF
Lab ID: B19062378-001A

Report Date: 06/28/19
Collection Date: 06/25/19 11:15
Received Date: 06/26/19 07:45
Matrix: Drinking Water
Sampled By: Jim Brown

Compliance Sample: YES **Sample Type:** RT

Residual Chlorine (Field): 0.36

Analyses	Result	Units	Safe/Unsafe	Qualifier	Method	Analysis Date / By
MICROBIOLOGICAL						
3100 Coliform, Total	Absent	per 100ml	SAFE		A9223 B	06/26/19 08:47 / ean
3014 Coliform, E-Coli	Absent	per 100ml			A9223 B	06/26/19 08:47 / ean

Comments: The notation "SAFE" indicates that the water was bacteriologically SAFE when sampled.
The notation "UNSAFE" indicates that the water was bacteriologically UNSAFE when sampled.

Method Reference: E - EPA / MCAWW Methodology A - Standard Methods 22nd Ed.



Trust our People. Trust our Data.
www.energylab.com

Billings, MT 800.735.4489 • Casper, WY 888.235.0515
Gillette, WY 866.686.7175 • Helena, MT 877.472.0711

LABORATORY ANALYTICAL REPORT

Prepared by Billings, MT Branch

Client: Malta City of
Project: MT0000284
Client Sample ID: City Hall
PWS ID: MT0000284 **Facility ID:** DS001 **Sample Point ID:** SP001
Facility Name: MALTA CITY OF
Lab ID: B19062378-002A

Report Date: 06/28/19
Collection Date: 06/25/19 11:26
Received Date: 06/26/19 07:45
Matrix: Drinking Water
Sampled By: Jim Brown

Compliance Sample: YES **Sample Type:** RT

Residual Chlorine (Field): 0.41

Analyses	Result	Units	Safe/Unsafe	Qualifier	Method	Analysis Date / By
MICROBIOLOGICAL						
3100 Coliform, Total	Absent	per 100ml	SAFE		A9223 B	06/26/19 08:47 / ean
3014 Coliform, E-Coli	Absent	per 100ml			A9223 B	06/26/19 08:47 / ean

Comments: The notation "SAFE" indicates that the water was bacteriologically SAFE when sampled.

The notation "UNSAFE" indicates that the water was bacteriologically UNSAFE when sampled.

Method Reference: E - EPA / MCAWW Methodology A - Standard Methods 22nd Ed.