



Trust our People. Trust our Data.
www.energylab.com

Billings, MT 800.735.4489 • Casper, WY 888.235.0515
Gillette, WY 866.686.7175 • Helena, MT 877.472.0711

LABORATORY ANALYTICAL REPORT

Prepared by Billings, MT Branch

Client: Malta City of
Project: MT0000284
Client Sample ID: Horizon Resources
PWS ID: MT0000284 **Facility ID:** DS001 **Sample Point ID:** SP001
Facility Name: MALTA CITY OF
Lab ID: B19111828-001A

Report Date: 11/22/19
Collection Date: 11/20/19 11:35
Received Date: 11/21/19 07:45
Matrix: Drinking Water
Sampled By: Jim Truelove

Compliance Sample: YES

Sample Type: RT

Residual Chlorine (Field): 0.30

Analyses	Result	Units	Safe/Unsafe	Qualifier	Method	Analysis Date / By
MICROBIOLOGICAL						
3100 Coliform, Total	Absent	per 100ml	SAFE		A9223 B	11/21/19 09:06 / fap
3014 Coliform, E-Coli	Absent	per 100ml			A9223 B	11/21/19 09:06 / fap

Comments: The notation "SAFE" indicates that the water was bacteriologically SAFE when sampled.

The notation "UNSAFE" indicates that the water was bacteriologically UNSAFE when sampled.

Method Reference: E - EPA / MCAWW Methodology A - Standard Methods 22nd Ed.



Trust our People. Trust our Data.
www.energylab.com

Billings, MT 800.735.4489 • Casper, WY 888.235.0515
Gillette, WY 866.686.7175 • Helena, MT 877.472.0711

LABORATORY ANALYTICAL REPORT

Prepared by Billings, MT Branch

Client: Malta City of
Project: MT0000284
Client Sample ID: City Hall
PWS ID: MT0000284 **Facility ID:** DS001 **Sample Point ID:** SP001
Facility Name: MALTA CITY OF
Lab ID: B19111828-002A

Report Date: 11/22/19
Collection Date: 11/20/19 11:47
Received Date: 11/21/19 07:45
Matrix: Drinking Water
Sampled By: Jim Truelove

Compliance Sample: YES **Sample Type:** RT

Residual Chlorine (Field): 0.34

Analyses	Result	Units	Safe/Unsafe	Qualifier	Method	Analysis Date / By
MICROBIOLOGICAL						
3100 Coliform, Total	Absent	per 100ml	SAFE		A9223 B	11/21/19 09:06 / fap
3014 Coliform, E-Coli	Absent	per 100ml			A9223 B	11/21/19 09:06 / fap

Comments: The notation "SAFE" indicates that the water was bacteriologically SAFE when sampled.

The notation "UNSAFE" indicates that the water was bacteriologically UNSAFE when sampled.

Method Reference: E - EPA / MCAWW Methodology A - Standard Methods 22nd Ed.